



**DEPARTMENT OF THE NAVY**  
U. S. NAVAL SUPPORT ACTIVITY NAPLES ITALY  
PSC 817 BOX 1  
FPO AE 09622-0001

6260  
Ser.N00/ 1698  
28 DEC 2021

**From:** Commanding Officer, U.S. Naval Support Activity, Naples, Italy  
**To:** Parents and Staff, Carney Park Recreational and Teen Centers, U.S. Naval Support Activity, Naples, Italy

**Subj:** U.S. NAVAL SUPPORT ACTIVITY, NAPLES, ITALY CARNEY PARK RECREATIONAL AND TEEN CENTERS' DRINKING WATER


**Encl:** (1) Carney Park Rec-Teen Centers Complete Test Results

1. The Navy is committed to maintaining safe drinking water on its installations. Our drinking water distribution system is regularly tested for lead and is in compliance with the Environmental Protection Agency's (EPA) Lead and Copper Rule and the Safe Drinking Water Act.
2. Lead exposure is a particular concern for children. Lead in drinking water typically comes from the plumbing inside buildings including lead service lines, fittings, solder, water fountains/coolers, or water faucets. The Navy policy requires we test the lead content of drinking water in priority areas such as Youth-Teen Centers (YTCs), schools, and Child Development Centers (CDCs) every five years. Testing at both the Carney Park Recreational Center and at the Teen Center was conducted on 27 March 2021.
3. I am pleased to report that all drinking water intended for consumption, to include drinking water and water intended for cooking or washing, is at or below the Navy lead screening level of 15 parts per billion (PPB).
4. Navy environmental personnel conducted this testing at the Carney Park Recreational Center and at the Teen Center following Navy policy. In all, two samples were taken and sent to the U.S. Army Public Health Center certified laboratory for analysis.
5. A copy of all test results is enclosed for your information.
  - a. To learn more about lead in drinking water in schools and day care centers visit the following EPA website: <https://www.epa.gov/dwreginfo/lead-drinking-water-schools-and-child-care-facilities>.
  - b. To learn more about the installation water quality, see the annual water quality report: [https://www.cnic.navy.mil/regions/cnreurafcnt/installations/nsa\\_naples/om/environmental\\_support/drinking\\_water\\_consumer\\_confidence\\_report.html](https://www.cnic.navy.mil/regions/cnreurafcnt/installations/nsa_naples/om/environmental_support/drinking_water_consumer_confidence_report.html)
6. While lead in the drinking water at these facilities is below the Navy screening levels for schools and daycare centers, if you have any health questions or concerns, I encourage you to set up a virtual visit with your health care provider through TRICARE Online or call the U.S Naval

Subj: U.S. NAVAL SUPPORT ACTIVITY, NAPLES, ITALY CARNEY PARK  
RECREATIONAL AND TEEN CENTERS' DRINKING WATER

Hospital, Naples, Italy main appointment line (629-6000, or 081-11-6000). Virtual Visits afford the time required for you to address particular concerns with your primary care provider.

7. For further information, please contact LT Jamie E. Moroney, Public Affairs Officer, at DSN: 314-626-5912, COMM: +39-081-568-5912, or e-mail: [jamie.moroney@eu.navy.mil](mailto:jamie.moroney@eu.navy.mil).



J. W. STEWART

Copy to:  
CNIC N45  
NAVFAC N45

Summary Results Table  
 Priority Areas Lead Testing and Corrective Actions (2021)  
 NSA NAPLES Carney Park Rec - Teen Centers  
 Bldgs. 524 - 544

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST-CORRECTIVE ACTION SAMPLING RESULTS	
CATEGORY  [Water's intended use]	SAMPLE ID  [Use same nomenclature as baseline sample event]	Outlet Description  [At a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]	Comments  [Provide, for example, whether filter was removed, staining was present, any identifying marks]	Lead Screening Level of 15 ppb			Lead Screening Level of 15 ppb			Description  [Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]	Recommended Level = 15 ppb	
				First Draw (ppb)  [numeric value]	Retest required?  [YES or NO]	Date Fixture Secured? (See Note 1)  [N/A if First Draw is ≤ 15ppb; otherwise mm/dd/yyyy]	Water Fountain/Chiller 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)  [numeric value]	First Draw (ppb)  [numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)  [numeric value]		First Draw (ppb) (See note 2)  [numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)  [numeric value]
SAMPLING DATE				3/13/2021			mm/dd/yyyy	7/1/2021	7/1/2021		mm/dd/yyyy	
RESULTS DATE				05/20-24/2021			mm/dd/yyyy	7/23/2021	7/23/2021		mm/dd/yyyy	
WASHING	CP-YTC-LP-001	Bldg. 524 Room kitchen sink		2.9	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	CP-REC-LP-001	Bldg. 544 Room kitchen sink		0	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Notes:

<sup>1</sup> Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 15 ppb.

<sup>2</sup> Post-remediation sampling was initially conducted on[ENTER DATE]. Additional [CORRECTIVE ACTIONS DESCRIPTION] were implemented and final results below recommended level of 15ppb for sample collected on[ENTER DATE] are shown on the table.

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST-CORRECTIVE ACTION RESULTS
	Lead Screening Level of 15 ppb				
	First Draw (ppb)	Water Fountain	First Draw (ppb)	Follow up Flush	First Draw (ppb)
Total Drinking	0	N/A	0	0	N/A
Total Drinking > 15 ppb	0	N/A	0	0	N/A
Total Cook	0	N/A	0	0	N/A
Total Cook > 15 ppb	0	N/A	0	0	N/A
Total Washing	2	N/A	0	0	N/A
Total Washing > 15 ppb	0	N/A	0	0	N/A
Total Samples	2	N/A	0	0	N/A
Total Samples > 15 ppb	0	N/A	0	0	N/A